



8431 Murphy Drive  
Middleton, WI 53562 USA

Telephone: 608.836.4400  
Facsimile: 608.831.9279  
www.intertek.com

# Test Verification of Conformity

In the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out.


<b>Applicant Name &amp; Address:</b>	Calmonte Corporation 9628 Valley Blvd. Rosemead, CA 91770 USA
<b>Product Description:</b>	Photovoltaic Mount
<b>Ratings &amp; Principle Characteristics:</b>	<u>Fire Class Resistance Rating:</u> -Flush Mount (Symmetrical). Class A Fire Rated for Steep Slope applications when using Type 1 listed photovoltaic modules. Tested with a 5" gap (distance between the bottom the module frame and the roof covering), per the standard this system can be installed at any gap allowed by the manufacturers installation instructions. No perimeter guarding is required.
<b>Models:</b>	SWH – Standoff PV Racking
<b>Brand Name:</b>	Solar Warehouse
<b>Relevant Standards:</b>	UL 2703 (Section 15.2 and 15.3) Standard for Safety Mounting Systems, Mounting Devices, Clamping/Retention Devices, and Ground Lugs for Use with Flat-Plate Photovoltaic Modules and Panels, First Edition dated Jan. 28, 2015 <b>Referencing</b> UL1703 Third Edition dated Nov. 18, 2014, (Section 31.2) Standard for Safety for Flat-Plate Photovoltaic Modules and Panels.
<b>Verification Issuing Office:</b>	Intertek Testing Services NA, Inc. 8431 Murphy Drive Middleton, WI 53562
<b>Date of Tests:</b>	3/18/2015 to 03/20/2015
<b>Test Report Number(s):</b>	101988205MID-001.
<b>This verification is part of the full test report(s) and should be read in conjunction with them. This report does not automatically imply product certification. This Test Verification of Conformity document may be used as a Letter of Compliance (LOC), as the above has met the relevant fire requirements of the standard.</b>	
<b>Completed by:</b>	Chad Naggs
<b>Title:</b>	Technician II, Fire Resistance
<b>Signature:</b>	
<b>Date:</b>	03/30/2015
<b>Reviewed by:</b>	Gregory Allen
<b>Title:</b>	Engineering Team Lead, Fire Resistance
<b>Signature:</b>	
<b>Date:</b>	03/30/2015

*This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.*



# Test Verification of Conformity

In the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out.

<b>Applicant Name &amp; Address:</b>	Calmonte Corporation 9628 Valley Blvd. Rosemead, CA 91770		
<b>Product Description:</b>	Photovoltaic Roof Mount System.		
<b>Ratings &amp; Principle Characteristics:</b>	<u>Fire Class Resistance Rating:</u> - Class A for Steep Slope applications when using Type 2, listed photovoltaic modules and a Fire Rated roof. Testing was conducted with a 5" gap between the module and the roof surface.		
<b>Models:</b>	Solar Warehouse PV mounting System		
<b>Brand Name:</b>	Solar Warehouse		
<b>Relevant Standards:</b>	UL Subject 2703 (Section 15.2 and 15.3) Outline of Investigation for Rack Mounting Systems and Clamping Devices for Flat-Plate Photovoltaic Modules and Panels, First Edition, January 28, 2015 <b>Referencing</b> UL1703 Third Edition(Section 31.2) Standard for Safety for Flat-Plate Photovoltaic Modules and Panels, Oct. 2015.		
<b>Verification Issuing Office:</b>	Intertek Testing Services NA, Inc. 8431 Murphy Drive Middleton, WI 53562 USA		
<b>Date of Tests:</b>	10/28/2015-10/29/2015		
<b>Test Report Number(s):</b>	102270334MID-001		
<b>This verification is part of the full test report(s) and should be read in conjunction with them. This report does not automatically imply product certification.</b>			
<b>Completed by:</b>	Christopher Zimbrich	<b>Reviewed by:</b>	Gregory Allen
<b>Title:</b>	Technician II, Fire Resistance	<b>Title:</b>	Engineering Team Lead, Fire Resistance
<b>Signature:</b>		<b>Signature:</b>	
<b>Date:</b>	10/30/2015	<b>Date:</b>	10/30/2015

*This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.*